



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **A**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according article 3 of point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20°C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.
POL. IND. USABAL, 24. TOLOSA-GIPUZKOA.
TLF: 943-67.33.99. FAX: 943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **A-LUG**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according point 3 of article 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.
AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA
TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **AB**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according article 3 of point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20°C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.
POL. IND. USABAL, 24. TOLOSA-GIPUZKOA.
TLF: 943-67.33.99. FAX: 943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **C**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according article 3 point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.

Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.

AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA-SPAIN

TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY EC

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valve type **D**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999** & **European Parliament and Commission Directive 97/23/EC** according article 3 of point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.
AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA
TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE LA CALIDAD CERTIFICADA

QUALITY MANAGEMENT CERTIFIED

DECLARATION CONFORMITY EC

CARMELO DÍEZ, as General Manager of **C.M.O** declares under his responsibility, that the valves **type D**, designed as anti-return systems, for dangerous (G1) and non-dangerous liquids (Group 2), see below table, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC**, relative to under pressure equipment, marked under category I or according point 3 of article 3 when being applicable, analyzed as pipelines for liquid transport, which pressure at ambient conditions must be higher to 0.5 bar.



Carmelo Díez
General Manager

Tolosa, Tuesday, June 10, 2008

UP TO CAT. I G2

ND	PN10	PN16	PN25	PN40	PN64
50	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3
65	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3
80	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
100	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
125	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I	CAT I
150	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I	CAT I
200	P 3 ART 3	P 3 ART 3	CAT I	CAT I	CAT I
250	P 3 ART 3	P 3 ART 3	CAT I	CAT I	CAT I
300	P 3 ART 3	P 3 ART 3	CAT I	CAT I	CAT I
350	P 3 ART 3	CAT I	CAT I	CAT I	CAT I
400	P 3 ART 3	CAT I	CAT I	CAT I	CAT I
450	P 3 ART 3	CAT I	CAT I	CAT I	CAT I
500	CAT I	CAT I	CAT I	CAT I	CAT I
600	CAT I	CAT I	CAT I	CAT I	CAT I

UP TO CAT. I G1

ND	PN10	PN16	PN25	PN40
50	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
65	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
80	P 3 ART 3	P 3 ART 3	CAT I	CAT I
100	P 3 ART 3	P 3 ART 3	CAT I	
125	P 3 ART 3	CAT I	CAT I	
150	P 3 ART 3	CAT I		

C.M.O.

AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA-SPAIN

TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **E**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according article 3 point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.

AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA-SPAIN

TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **K**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according article 3 point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.

AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA-SPAIN

TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **L**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC** according article 3 point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.

AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA-SPAIN

TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE LA CALIDAD CERTIFICADA

QUALITY MANAGEMENT CERTIFIED

DECLARATION CONFORMITY EC

CARMELO DÍEZ, as General Manager of **C.M.O** declares under his responsibility, that the valves **type R**, designed as anti-return systems, for dangerous (G1) and non-dangerous liquids (Group 2), see below table, meets the requirements and dispositions agreed in the **Royal Decree 769/1999 & European Parliament and Commission Directive 97/23/EC**, relative to under pressure equipment, marked under category I or according point 3 of article 3 when being applicable, analyzed as pipelines for liquid transport, which pressure at ambient conditions must be higher to 0.5 bar.



Carmelo Díez
General Manager

Tolosa, Thursday, June 04, 2009

UP TO CAT. I G2

ND	PN10	PN16	PN25	PN40	PN64
50	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3
65	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3
80	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
100	P 3 ART 3	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
125	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I	CAT I
150	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I	CAT I
200	P 3 ART 3	P 3 ART 3	CAT I	CAT I	CAT I
250	P 3 ART 3	P 3 ART 3	CAT I	CAT I	CAT I
300	P 3 ART 3	P 3 ART 3	CAT I	CAT I	CAT I
350	P 3 ART 3	CAT I	CAT I	CAT I	CAT I
400	P 3 ART 3	CAT I	CAT I	CAT I	CAT I
450	P 3 ART 3	CAT I	CAT I	CAT I	CAT I
500	CAT I	CAT I	CAT I	CAT I	CAT I
600	CAT I	CAT I	CAT I	CAT I	CAT I

UP TO CAT. I G1

ND	PN10	PN16	PN25	PN40
50	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
65	P 3 ART 3	P 3 ART 3	P 3 ART 3	CAT I
80	P 3 ART 3	P 3 ART 3	CAT I	CAT I
100	P 3 ART 3	P 3 ART 3	CAT I	
125	P 3 ART 3	CAT I	CAT I	
150	P 3 ART 3	CAT I		

C.M.O.

AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA-SPAIN

TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02



CONSTRUCCIONES METÁLICAS DE OBTURACIÓN, S.L.



GESTION DE
LA CALIDAD
CERTIFICADA

QUALITY
MANAGEMENT
CERTIFIED

DECLARATION OF CONFORMITY

CARMELO DÍEZ, as General Manager of **C.M.O** declares under my responsibility, that the valves type **A**, meets the requirements and dispositions agreed in the **Royal Decree 769/1999** & **European Parliament and Commission Directive 97/23/EC** according article 3 of point 3, relative to pressure equipments, under the category of valves for fluids of **group G2**, for work at 20° C, analyzed as pipelines for liquid transport, whose vapor pressure, at maximal allowed temperature, be not higher in more than 0.5 bar at atmospheric pressure.



Carmelo Díez
General Manager

Tolosa, Tuesday, December 09, 2008

C.M.O.
AMATEGUI ALDEA 142, TXARAMA-TOLOSA-GUIPUZCOA
TLF:943-67.33.99.FAX:943.67.24.40

cmo@cmo.es --- WWW.CMO.ES

DOC-06.01.03 Rev 02